



ZIONSVILLE WASTEWATER DEPARTMENT

SEPTEMBER 2017 MONTHLY REPORT

STATS FOR MONTH	SEPT 2017	SEPT 2016	SEPT 2015
Total Flow	22.25 MG	30.45 MG	27.92 MG
Highest Daily Flow	0.907 MG	2.018 MG	1.776 MG
Average Daily Flow	0.742 MG	1.015 MG	0.931 MG
Precipitation	0.26 IN	6.67 IN	2.79 IN
Percent Plant Capacity	37 %	51 %	47 %
NPDES Violations	0	0	0

Additional Comments:

Completed the 2017 sewer rehab project on 9/28, which consisted of sewer lining in Sugarbush subdivision, Bloor Lane, Terrace Dr, and Mulberry Street.

Added a backup pump at Boone Village lift station to help with any future lift station problems and as a lead pump in wet weather situations.