



ZIONSVILLE WASTEWATER DEPARTMENT
 MONTHLY REPORT
 OCTOBER 2017

STATS FOR MONTH	OCT 2017	OCT 2016	OCT 2015
Total Monthly Flow	24.10 MG	27.21 MG	31.59 MG
Highest Daily Flow	1.067 MG	1.346 MG	1.232 MG
Average Daily Flow	0.777 MG	0.878 MG	1.019 MG
Precipitation	3.99 IN	2.60 IN	1.72 IN
Percent Plant Capacity	39%	44%	51%
NPDES Violations	0	0	0

Additional Comments:

Cummins Crosspoint performed the preventative maintenance on all 18 of the department's emergency generators. Found problems with 5 of them and are working to correct these issues. The next service will be in 6 months and at that time will probably have added 3 more generators from new subdivisions that the department will be responsible for.

Boilermasters performed the preventative maintenance on 2 of the department's boilers and found no problems. The next service will be in 6 months.

Finished up a department sanitary sewer video and spot cleaning project in Smith Meadows, Cedar Bend, and Oakridge subdivisions. Found several manholes that were buried and uncovered them. Cleaned some grease deposits that were in a few locations. The majority of the sanitary mains looked good. No major issues found.

Chlorination season ended on 10/31/17. Will begin again at the end of March 2018.