



ZIONSVILLE WASTEWATER DEPARTMENT

MONTHLY REPORT

NOVEMBER 2018

STATS FOR MONTH	NOV 2018	NOV 2017	NOV 2016
Total Flow	35.77 MG	28.72 MG	25.88 MG
Highest Daily Flow	2.130 MG	1.796 MG	1.521 MG
Average Daily Flow	1.192 MG	0.957 MG	0.863 MG
Precipitation	4.44 IN	4.50 IN	2.81 IN
Percent Plant Capacity	60 %	48%	43%
NPDES Violations	0	0	0

Additional Comments:

Merrell Bros finished hauling biosolids out of the treatment plant and to their dry storage facility on 11/1.

Completed 2 alley sewer replacements off of Third Street during the month per the 2018 Sewer Rehab project. The third will be completed next spring.

The northern alley required new asphalt as the alley condition was not in good shape before the sewer work began. This work has been completed and concludes the 2018 Sewer Rehab Project for the year.

Backflow preventers were certified at several locations around Town properties as per Citizens requirements.

Thornhill lift station generator was repaired and is now operable. Had problems with mice chewing through the wires again.