



ZIONSVILLE WASTEWATER DEPARTMENT

MONTHLY REPORT

MARCH 2019

STATS FOR MONTH	March 2019	March 2018	March 2017
Total Flow	39.62 MG	38.03 MG	35.86 MG
Highest Daily Flow	2.41 MG	2.30 MG	2.05 MG
Average Daily Flow	1.28 MG	1.23 MG	1.16 MG
Precipitation	5.09 IN	4.39 IN	5.13 IN
Percent Plant Capacity	64 %	61 %	58 %
NPDES Violations	0	0	0

Additional Comments:

Completed the SCADA upgrade with new hardware at the plant. Precision Controls performed the work. Have one PLC left to change out and some addition small things to completely finish up the job.

Security Pros performed some more work at the plant with the installation of 2 more cameras.

Attended multiple meetings during the month including engineering, sewer bonds, FOG, Atlas – Compressor PM's, Cummins – Generator PM's, and plant improvement meetings.

Concluded the month of March with a week of wet weather including a total of 2.5" of rain that left the ground saturated.