



ZIONSVILLE WASTEWATER DEPARTMENT

MONTHLY REPORT

AUGUST 2019

STATS FOR MONTH	AUG 2019	AUG 2018	AUG 2017
Total Flow	26.88 MG	31.65 MG	26.20 MG
Highest Daily Flow	1.391 MG	1.750 MG	1.015 MG
Average Daily Flow	0.867 MG	1.021 MG	0.845 MG
Precipitation	4.35 IN	7.30 IN	1.18 IN
Percent Plant Capacity	43%	51%	42%
NPDES Violations	0	0	0

Additional Comments:

Attended several meetings, during the month, concerning future upgrades to the treatment plant, future collection system needs, looking into possibly utilizing solar power at the plant, and some current maintenance item needs at the treatment plant.

Security Pros is working on some more security measures at the plant including a few cameras. One is being installed at the outfall of the Wastewater Treatment plant that will be powered by solar panels and provide views of Eagle Creek, especially during flooding events.

Final plans have been submitted to the state for construction permits for a new storage building and renovating the existing Administration building from a garage bay and workshop to new office space. Both projects will hopefully get the green light to start soon.

Attended biweekly meetings with BLN to discuss all of the major construction sewer projects – mainly the Northeast Regional lift station (Holliday property) and Oak Street sewer projects. Also continuing the process of updating the Department's design and construction standards.