



ZIONSVILLE WASTEWATER DEPARTMENT
MONTHLY REPORT

STATS FOR MONTH	April 2015	April 2014	April 2013
Total Flow	47.95 MG	47.48 MG	57.73 MG
Highest Daily Flow	3.34 MG	4.46 MG	5.80 MG
Average Daily Flow	1.60 MG	1.58 MG	1.92 MG
Precipitation	6.25 IN	6.70 IN	10.50 IN
Percent Plant Capacity	80%	79%	96%
NPDES Violations	0	1	4

Additional Comments: