



ZIONSVILLE WASTE WATER DEPARTMENT
MONTHLY REPORT

	<u>APRIL 2014</u>	<u>APRIL 2013</u>
TOTAL FLOW	47.48 MG	57.73 MG
HIGHEST DAILY FLOW	4.46 MG	5.80 MG
AVERAGE DAILY FLOW	1.583 MG	1.924 MG
PRECIPITATION	6.7 in	10.5 in
NPDES VIOLATIONS	1	4
PERCENT FLOW CAPACITY	79%	96%

ADDITIONAL COMMENTS:

- The one violation of the month occurred on April 3rd after receiving over 3.5 inches of rain within a 6 hour period causing an overflow of the Boone Village Lift Station at the plant site. The overflow lasted for 2.5 hours. As required by our permit the IDEM was notified of the incident and the area was cleaned up following the storm.
- The first quarter budget report was supplied to the Town Manager for distribution to the Town Council. The department has experienced some unusual expenses so far this year resulting from the harsh winter, replacing an Operator 1 with an Operator 2, and unexpected equipment repair costs. With this only being the 1st quarter it is difficult to project a year's end balance but I suspect we will have enough money to re-appropriate to offset the current projected deficits.

