

# ZIONSVILLE WASTE WATER MONTHLY REPORT



	<u>DECEMBER 2014</u>	<u>DECEMBER 2013</u>
TOTAL FLOW	33.60 MG	35.02 MG
HIGHEST DAILY FLOW	1.57MG	3.74 MG
AVERAGE DAILY FLOW	1.084 MG	1.113 MG
PRECIPITATION	2.6 in	3.8 in
NPDES VIOLATIONS	0	0
PERCENT FLOW CAPACITY	54 %	56%

ADDITIONAL COMMENTS: