



ZIONSVILLE WASTE WATER DEPARTMENT  
MONTHLY REPORT

	<u>JANUARY 2014</u>	<u>JANUARY 2013</u>
TOTAL FLOW	38.30 MG	43.35 MG
HIGHEST DAILY FLOW	2.02 MG	4.29 MG
AVERAGE DAILY FLOW	1.24 MG	1.45 MG
PRECIPITATION	3.05 in	6.4in
NPDES VIOLATIONS	0	2
PERCENT FLOW CAPACITY	62%	72%

ADDITIONAL COMMENTS: