



ZIONSVILLE WASTE WATER DEPARTMENT  
MONTHLY REPORT

|                       | <u>APRIL 2013</u> | <u>APRIL 2012</u> |
|-----------------------|-------------------|-------------------|
| TOTAL FLOW            | 57.73 MG          | 27.37 MG          |
| HIGHEST DAILY FLOW    | 5.80 MG           | 1.112 MG          |
| AVERAGE DAILY FLOW    | 1.924 MG          | 0.912 MG          |
| PRECIPITATION         | 10.5 in           | 2.2 in            |
| NPDES VIOLATIONS      | 4                 | 0                 |
| PERCENT FLOW CAPACITY | 96%               | 46%               |

ADDITIONAL COMMENTS:

- The four violations for the month are as follows: One from a manhole overflowing on 4/8 due to a blockage in the main line. The blockage was cleared by the Street Department the same day. The other three violations were as a result of 6.3 inches of rain during the week of 4/16 through 4/20. The worst day was 4/19 when 4.6 inches of rain came down in a 12hr period. The collection system overflowed, the Equalization tank filled and overflowed at the treatment plant, and we exceeded the amount of suspended solids allowed on a weekly basis for that same week. Exceeding the allowed weekly suspended solids can be attributed to our treatment ponds being flooded and filled with silt laden flood waters from Eagle Creek.
- The first quarter budget report was supplied to the Town Manager for distribution to the Town Council. The department has not experienced any unusual expenses so far this year that would present problems staying within the approved budget for 2013.
- The 2013 Sewer Rehabilitation Project will receive and open bids on Friday, May 10, at 3:00pm at the Zionsville Town Hall.

