



ZIONSVILLE WASTE WATER DEPARTMENT

	<u>AUGUST 2013</u>	<u>AUGUST 2012</u>
TOTAL FLOW	24.66 MG	24.03 MG
HIGHEST DAILY FLOW	0.964 MG	0.975 MG
AVERAGE DAILY FLOW	0.795 MG	0.775 MG
PRECIPITATION	1.3 in	4.3 in
NPDES VIOLATIONS	1	0
PERCENT FLOW CAPACITY	40%	39%

ADDITIONAL COMMENTS:

- The one violation for the month happened on Sunday the 25th and was caused by a blockage in a low pressure force main located in the Woodlands at Irishman’s Run that resulted in some home owner’s pump pits to fill and overflow. This is the third time this year that we responded to problems in the line and unlike the previous two where we were able to clear the blockage with sewer cleaning equipment, we were unable to clear the line. We finally narrowed the problem to a buried check valve that we had to excavate and repair. Service was restored temporarily by a pumper truck provided by Fluid Waste Services and the repair was completed early Monday afternoon.
- The 2013 Sewer Rehabilitation Project is nearly complete with the exception of some minor punch list items and finalizing a change order that allowed for additional sewer segments to be rehabilitated.

