

ZIONSVILLE WASTE WATER MONTHLY REPORT



	<u>DECEMBER 2013</u>	<u>DECEMBER 2012</u>
TOTAL FLOW	35.02 MG	31.8 MG
HIGHEST DAILY FLOW	3.74 MG	1.403 MG
AVERAGE DAILY FLOW	1.1.13 MG	1.026 MG
PRECIPITATION	3.8 in	3.4 in
NPDES VIOLATIONS	0	0
PERCENT FLOW CAPACITY	56%	51%

ADDITIONAL COMMENTS:

The highest flow for the month occurred on December 22nd after a snow melt off followed by 3.0 inches of precipitation on the 21st and 22nd. The collection system and wastewater plant had no violations of our discharge permit during that event.

ZIONSVILLE WASTE WATER MONTHLY REPORT