



ZIONSVILLE WASTE WATER DEPARTMENT
MONTHLY REPORT

	<u>JANUARY 2013</u>	<u>JANUARY 2012</u>
TOTAL FLOW	43.35 MG	43.44 MG
HIGHEST DAILY FLOW	4.29 MG	2.17 MG
AVERAGE DAILY FLOW	1.45 MG	1.40MG
PRECIPITATION	6.4 in	3.7in
NPDES VIOLATIONS	2	0
PERCENT FLOW CAPACITY	72%	70%

ADDITIONAL COMMENTS:

- We had two violations of our operating permit in January and both occurred on the 13th of the month. One was from an overflow from the Boone Village Lift Station when two of the three pumps became clogged with debris and the station could not keep up with the increased flow from over 4inches of rain in a 48 hour period. The other violation was from our equalization tank overflowing, blending with our treated flow and treated through our polishing ponds. The discharge from this blended overflow was sampled and within our permit guidelines in regards to all parameters. Notification was made to IDEM within the required 24hrs period.
- We had a small diameter force main become clogged in the Woodlands at Irishman’s Run development on January 24th causing numerous small grinder stations not functioning. The location of the blockage was determined rather quickly, The Snider Group and Fluid Waste Services were contracted to clear the line, and service was restored that same day.

