



ZIONSVILLE WASTE WATER DEPARTMENT
MONTHLY REPORT

	<u>JUNE 2013</u>	<u>JUNE 2012</u>
TOTAL FLOW	38.32 MG	22.4 MG
HIGHEST DAILY FLOW	2.052 MG	0.953 MG
AVERAGE DAILY FLOW	1.277 MG	0.748 MG
PRECIPITATION	7.6 in	0.73 in
NPDES VIOLATIONS	0	0
PERCENT FLOW CAPACITY	64%	37%

ADDITIONAL COMMENTS:

- Work has started on the 2013 Sewer Rehabilitation Project with cleaning and televising sewers along Williamsburg Ct., Williamsburg Ln, Bennington Dr, Blackstone, and Royal Oak Ct. in the Colony Woods subdivision. Some clearing of vegetation is necessary for the contractor to clean and televise the Colony Woods Trunk Sewer before lining can begin.

