



ZIONSVILLE WASTE WATER DEPARTMENT
MONTHLY REPORT

	<u>MAY 2013</u>	<u>MAY 2012</u>
TOTAL FLOW	36.66 MG	31.33 MG
HIGHEST DAILY FLOW	1.516 MG	1.795 MG
AVERAGE DAILY FLOW	1.182 MG	1.011 MG
PRECIPITATION	4.4 in	3.2 in
NPDES VIOLATIONS	0	0
PERCENT FLOW CAPACITY	59%	51%

ADDITIONAL COMMENTS:

- The treatment plant experienced a power outage on May 31, 2013 as a result of a power pole being hit by lightning. Power was restored in about 8hrs but the power company restored the power incorrectly resulting in \$3400 worth of damage to one of our secondary clarifiers. A damage claim was filed with Duke Energy and has been approved by their insurance carrier.
- Bids were received for the 2013 Sewer Rehabilitation Project and opened on May 10th at the Town Hall. The lowest bid was submitted by Insituform Technologies USA, Inc. at \$273,961. The second lowest bid was by Layne Inliner LLC, at \$285,863. The low bidder has done sewer projects for the Town in the past with excellent results. This year's project will involve the remainder of the Colony Woods Trunk Sewer and sewers along Williamsburg Ct., Williamsburg Ln, Bennington Dr, Blackstone, and Royal Oak Ct. in the Colony Woods subdivision. The project is to be completed by November 23, 2013.
- The Town has received our Draft NPDES Permit Renewal. IDEM will publish a general notice of a 30 day comment period, in the newspaper with the largest general circulation within Boone County, in

order to solicit input from interested parties, including the general public. All conditions and parameters contained within the Draft NPDES Permit are identical to our current NPDES Permit that expires on December 31, 2013.