



ZIONSVILLE WASTE WATER DEPARTMENT
MONTHLY REPORT

	<u>APRIL 2012</u>	<u>APRIL 2011</u>
TOTAL FLOW	27.37 MG	48.20 MG
HIGHEST DAILY FLOW	1.112 MG	4.578 MG
AVERAGE DAILY FLOW	0.912 MG	1.608 MG
PRECIPITATION	2.2 in	8.2 in
NPDES VIOLATIONS	0	1
PERCENT FLOW CAPACITY	46%	76%

ADDITIONAL COMMENTS:

- The 2012 Sewer Project is proceeding with Fluid Waste Services now having completed the cleaning and televising of sanitary sewers in Isenhour Hills, Bloor Lane, Terrace Drive, and Pine Meadows areas. Previous recordings made by Fluid Waste Services are currently being reviewed by our engineering firm, BLN. There were four sewer segments that were found in need of immediate repairs due to broken clay sewers. Those point repairs will be completed by Fluid Waste Services using a no dig “cured in place pipe technology”. This technology will enable the department to repair lines at a third of what conventional dig and repair costs are usually encountered.
- The IT upgrades for the Wastewater Department are completed. This included the replacement of four CPU’s, one laptop for on call operator use, monitors and printers. It also included new programming that allows operators, via the lap top, to interface with the SCADA program at the plant and monitor critical operations during off hours.

