

ZIONSVILLE WASTE WATER MONTHLY REPORT



	<u>DECEMBER 2012</u>	<u>DECEMBER 2011</u>
TOTAL FLOW	31.8 MG	48.14 MG
HIGHEST DAILY FLOW	1.403 MG	2.763 MG
AVERAGE DAILY FLOW	1.026 MG	1.553 MG
PRECIPITATION	3.4 in	5.4 in
NPDES VIOLATIONS	0	1
PERCENT FLOW CAPACITY	51%	78%

ADDITIONAL COMMENTS:

The rebuilding of Tertiary Pond #1 was completed by the end of December. Water will soon be added in order to test for any leaks. If additional work is required it will have to wait until weather conditions are conducive.