

ZIONSVILLE WASTE WATER MONTHLY REPORT



	<u>FEBRUARY 2012</u>	<u>FEBRUARY 2011</u>
TOTAL FLOW	31.73 MG	37.11 MG
HIGHEST DAILY FLOW	1.33 MG	5.42 MG
AVERAGE DAILY FLOW	1.09MG	1.325 MG
PRECIPITATION	1.5 in	5.9 in
NPDES VIOLATIONS	0	1
PERCENT FLOW CAPACITY	55%	65%

ADDITIONAL COMMENTS:

- The 2012 Sewer Project consists of the cleaning and televising of various subdivisions within the Town of Zionsville in order to prepare the next 10 year Rehabilitation and Replacement Program. The subdivision included in the cleaning and televising included Raintree, Sugarbush, Colony Woods, Irongate, and sections of sewer along Isenhour Drive, Terrace Drive, and Bloor Lane. Fluid Waste Services, Inc. have been contracted to do the cleaning and televising, and our Engineering firm, BLN, will review the results and provide recommendations for the next series of rehabilitation work. All of the chosen areas are served with the older clay sewers that are frequently found to have significant defects.
- I have attached a copy of last month's "Monthly Report of Operation" for the Councilor's review. From this report you can see that the statistics given above are just a small part of the monitoring required from the personnel of the Waste Water Department. Copies of each month are available for review at my office, if desired.

ZIONSVILLE WASTE WATER MONTHLY REPORT