



ZIONSVILLE WASTE WATER DEPARTMENT
MONTHLY REPORT

	<u>MAY 2012</u>	<u>MAY 2011</u>
TOTAL FLOW	31.33 MG	42.66 MG
HIGHEST DAILY FLOW	1.795 MG	2.806 MG
AVERAGE DAILY FLOW	1.011 MG	1.376 MG
PRECIPITATION	3.2 in	5.0 in
NPDES VIOLATIONS	0	0
PERCENT FLOW CAPACITY	51%	69%

ADDITIONAL COMMENTS:

- The 2012 Sewer Project is proceeding with Fluid Waste Services now having completed the cleaning and televising of sanitary sewers in the village area. There were four sewer segments that were found in need of immediate repairs due to broken clay sewers. Those point repairs were completed in May by Fluid Waste Services. A total of 3,150ft of 6in sanitary sewers were cleaned and televised in this area and a preliminary review shows most of the remaining old clay sewers are in need of repairs. To date a total of 29,000 lineal feet of sewers in the village area have been either replaced or relined.
- These and previous recordings made by Fluid Waste Services are currently being reviewed by our engineering firm, BLN, in order to develop another long range rehabilitation schedule.

