



ZIONSVILLE WASTE WATER DEPARTMENT
MONTHLY REPORT

	<u>NOVEMBER 2012</u>	<u>NOVEMBER 2011</u>
TOTAL FLOW	25.14 MG	34.67 MG
HIGHEST DAILY FLOW	1.215 MG	2.001 MG
AVERAGE DAILY FLOW	0.838 MG	1.156 MG
PRECIPITATION	1.3 in	5.6 in
NPDES VIOLATIONS	0	0
PERCENT FLOW CAPACITY	42%	58%

ADDITIONAL COMMENTS:

- Earth Resources, Inc. completed the clearing and reshaping of Polishing Pond #1 and is in the process of mixing the new bentonite liner. The project should be completed by the end of December.
- Maddox Industrial Contractors Inc. completed the planned repairs to the Main Lift Station in November. The project involved replacing the inlet valves to the two storm pumps while keeping the pumping station in service, was accomplished in two days and came in well under budget.

