

ZIONSVILLE WASTE WATER MONTHLY REPORT

	<u>JUNE 2011</u>	<u>JUNE 2010</u>
TOTAL FLOW	37.9 Million Gallons	41.6 Million Gallons
HIGHEST DAILY FLOW	2.95 Million Gallons	4.06 Million Gallons
AVERAGE DAILY FLOW	1.265 Million Gallons/Day	1.388 Million Gallons/Day
PRECIPITATION	6.0 in	11.4 in
NPDES VIOLATIONS	0	0

ADDITIONAL COMMENTS

- Contract documents and the Notice To Proceed were signed for the 2011 Sewer Project. The contractor, InsituformTecnologies USA, Inc has begun preliminary cleaning work on Pine, 4th, 5th, and 6th Streets along the Oak Street area. The contractor is also preparing an estimate for additional work for a portion of the Colony Woods Interceptor Sewer. This portion has experienced back-ups due to large root intrusions where the cleaning and lining would eliminate future problems.

Respectfully submitted,

Dennis Mackey
W.W. Dept. Superintendent

ZIONSVILLE WASTE WATER MONTHLY REPORT