

ZIONSVILLE WASTE WATER MONTHLY REPORT



	<u>OCTOBER 2011</u>	<u>OCTOBER 2010</u>
TOTAL FLOW	28.17 MG	23.06 MG
HIGHEST DAILY FLOW	2.08 MG	0.775 MG
AVERAGE DAILY FLOW	0.909 MG	0.744 MG
PRECIPITATION	3.3 in	1.5 in
NPDES VIOLATIONS	0	0

ADDITIONAL COMMENTS:

- The facility was inspected by Jason Palin of the IDEM on October the 13th. The plant was found to be operating efficiently and the operating, laboratory, and maintenance records were reviewed and appeared to be complete and accurate.
- We have received a quote from the contractor for the 2011 Sewer Rehabilitation Project to accomplish point repairs on the last sewer segment remaining in the project. This segment is located within the east/west alley bounded by 5th and 6th Streets on the east and west, and Cedar and Oak Streets on the north and south. They have been given the approval to proceed and those repairs should be done by the second week of November.
- The Zionsville Road Sewer Project is done with all of the punch list items being completed. Final completion papers will be submitted and the final pay estimate, with retainage, to be paid in December.
- The third quarter budget report was provided to the Town Manager and the Council for review. The 2011 budget for the Waste Water Department is expected to be contained within the budget for the year. I am currently estimating a budget surplus of approximately \$250,000 with most of that from the previously discussed polishing pond cleanout being delayed until next year. The remainder is from less than anticipated expenses in legal and engineering services and also in chemical supplies.
- Provided the proposed 2012 Wastewater Utility Budget to the Town Manager and Town Council for review.

ZIONSVILLE WASTE WATER MONTHLY REPORT