

ZIONSVILLE WASTE WATER MONTHLY REPORT

	<u>FEBRUARY 2010</u>	<u>FEBRUARY 2009</u>
TOTAL FLOW	29.39 MG	37.52 MG
HIGHEST DAILY FLOW	1.66 MG	4.65 MG
AVERAGE DAILY FLOW	1.05 MGD	1.34 MGD
PRECIPITATION	1.9 in	4.3 in
NPDES VIOLATIONS	0	3

ADDITIONAL COMMENTS:

- Work continues on design of the 2010 Sewer Rehabilitation Project. This project consists of the rehabilitation via re-lining of 3,800 lineal feet of sewers located on East Hawthorne, South Fourth, and West Sycamore Streets. An April bid opening is anticipated.
- Executed copies of Construction Agreement, Bonds, and Notice to Proceed were received from Weihe Construction, Inc. for the South Zionsville Road Sanitary Sewer Project. A pre-construction meeting was attended for this project and the contractor is currently sending submittals to HNTB for review. Actual construction should begin some time this month.

ZIONSVILLE WASTE WATER MONTHLY REPORT