



ZIONSVILLE WASTEWATER DEPARTMENT
MONTHLY REPORT

STATS FOR MONTH	JUNE 2015	JUNE 2014	JUNE 2013
Total Flow	41.6 MG	35.1 MG	38.3 MG
Highest Daily Flow	3.005 MG	1.633 MG	2.052 MG
Average Daily Flow	1.385 MG	1.168 MG	1.227 MG
Precipitation	9.2 IN	6.4 IN	7.6 IN
Percent Plant Capacity	69%	58%	64%
NPDES Violations	1	0	0

Additional Comments:

The one violation for the month occurred on June 19th after receiving 1.9 inches of rain that morning. We recorded 9 straight days with measurable precipitation with a total for that week of 4.89 inches. The 19th was the seventh consecutive day and also the heaviest rain event during this period. A manhole overflowed within the collection system for approximately 8 hours. As per our permit, IDEM was notified of the incident and the area was cleaned up after the storm. We are examining our options to keep this from happening again.