



ZIONSVILLE WASTEWATER DEPARTMENT
MONTHLY REPORT

STATS FOR MONTH	JULY 2015	JULY 2014	JULY 2013
Total Flow	50.51 MG	28.59 MG	29.11 MG
Highest Daily Flow	4.71 MG	1.16 MG	1.61 MG
Average Daily Flow	1.63 MG	0.92 MG	0.94 MG
Precipitation	9.85 IN	2.86 IN	2.27 IN
Percent Plant Capacity	81%	46%	47%
NPDES Violations	2	0	0

Additional Comments:

The 2 violations occurred on 8/13 to 8/14 and were due to the 3.44 inches of rain that evening and morning. They were both collection system overflows. One occurred at a manhole at the plant and another occurred at a manhole at the Main lift station. The plant treated 19.5 million gallons more than the normal monthly flow and we ended up with almost 10 inches of rain for the month. The two month precipitation total being 19.06 inches.

The 2015 Sewer Replacement project started at the end of July with cleaning and televising lines in Raintree and Colony Woods. Next will be ordering the liners and installing them on certain mains within these subdivisions. This work will be taking place, weather permitting, in the middle of August with completion by the end of the month.