



ZIONSVILLE WASTEWATER DEPARTMENT

MONTHLY REPORT

OCTOBER

STATS FOR MONTH	OCT 2015	OCT 2014	OCT 2013
Total Flow	31.59 MG	27.35 MG	27.82 MG
Highest Daily Flow	1.232 MG	1.425 MG	1.980 MG
Average Daily Flow	1.019 MG	0.882 MG	0.898 MG
Precipitation	1.72 IN	3.60 IN	4.70 IN
Percent Plant Capacity	51 %	44 %	45 %
NPDES Violations	0	0	0

Additional Comments: