



**ZIONSVILLE WASTEWATER DEPARTMENT**  
**MONTHLY REPORT**

STATS FOR MONTH	NOV 2015	NOV 2014	NOV 2013
Total Flow	29.27 MG	27.78 MG	29.91 MG
Highest Daily Flow	1.249 MG	2.184 MG	1.705 MG
Average Daily Flow	0.976 MG	0.926 MG	0.997 MG
Precipitation	3.54 IN	3.65 IN	5.70 IN
Percent Plant Capacity	49 %	46 %	50 %
NPDES Violations	0	0	0