



ZIONSVILLE WASTEWATER DEPARTMENT
MONTHLY REPORT

STATS FOR MONTH	DEC 2015	DEC 2014	DEC 2013
Total Flow Treated	35.37 MG	33.60 MG	35.02 MG
Highest Daily Flow	4.37 MG	1.57 MG	3.74 MG
Average Daily Flow	1.141 MG	1.084 MG	1.113 MG
Precipitation	6.49 IN	2.6 IN	3.8 IN
Percent Plant Capacity	57 %	54 %	56 %
NPDES Violations	0	0	0

Additional Comments:

Recorded 4.31 inches of rain for Sunday 11/27 thru Tuesday 11/29. Included in the total, were 3.00 inches on Sunday. Treated a total of 15.39 MG for the week, which is over twice the normal flow. Had three lift stations in high level, but all pumps were pumping and the flows were contained within the system.