



ZIONSVILLE WASTEWATER DEPARTMENT
MONTHLY REPORT

STATS FOR MONTH	JAN 2016	JAN 2015	JAN 2014
Total Flow Treated	35.39 MG	34.93 MG	38.30 MG
Highest Daily Flow	1.69 MG	1.26 MG	2.02 MG
Average Daily Flow	1.14 MG	1.13 MG	1.24 MG
Precipitation	1.52 IN	2.09 IN	3.05 IN
Percent Plant Capacity	57 %	56%	62%
NPDES Violations	0	0	0

Additional Comments:

Gaylor Electric replaced the automatic transfer switch, 2 breakers, and the electric panel at the Main Lift Station on Tuesday 1/26. The replaced equipment had been active since 1987. The department could no longer purchase replacement parts and the equipment had started to fail the last couple of years. The ATS is what controls the emergency generator and therefore the lift station during power outage situations.