



ZIONSVILLE WASTEWATER DEPARTMENT
MONTHLY REPORT

| STATS FOR MONTH | FEB 2016 | FEB 2015 | FEB 2014 |
|------------------------|----------|----------|----------|
| Total Flow | 25.1 MG | 27.1 MG | 35.9 MG |
| Highest Daily Flow | 1.74 MG | 1.17 MG | 2.34 MG |
| Average Daily Flow | 0.87 MG | 0.97 MG | 1.28 MG |
| Precipitation | 2.40 IN | 1.14 IN | 3.1IN |
| Percent Plant Capacity | 43 % | 48 % | 64 % |
| NPDES Violations | 0 | 0 | 0 |

Additional Comments:

Gaylor Electric replaced the automatic transfer switch, breaker and the electric panel at the Wastewater Treatment Plant on February 3rd. The original equipment was put into service at the same time as the Main Lift Station in 1987. The department could no longer purchase replacement parts and no longer had security that the transfer switch would do its job. The automatic transfer switch is what controls the

emergency generator and power to the treatment plant during power outage situations.