



ZIONSVILLE WASTEWATER DEPARTMENT
MONTHLY REPORT

STATS FOR MONTH	March 2016	March 2015	March 2014
Total Flow	35.41 MG	35.30 MG	35.46 MG
Highest Daily Flow	2.03 MG	2.02 MG	1.83 MG
Average Daily Flow	1.142 MG	1.14 MG	1.14MG
Precipitation	4.20 IN	3.94 IN	2.10 IN
Percent Plant Capacity	57 %	57 %	57 %
NPDES Violations	0	0	0

Additional Comments:

Maddox Industrial Group removed and replaced two 3000 gal tanks used to store sodium hypochlorite (bleach) for disinfection on 3/9. The tanks were in service since 2004 and had been slowly deteriorating.

Fluid Waste Services performed our spring lift station cleaning on 3/14 and 3/15. Twelve lift stations were cleaned within those 2 days.

They also cleaned out our chlorine contact tank on 3/16 before chlorination season officially begins on 4/1.