



ZIONSVILLE WASTEWATER DEPARTMENT
MONTHLY REPORT

STATS FOR MONTH	April 2016	April 2015	April 2014
Total Flow	34.36 MG	47.95 MG	47.48 MG
Highest Daily Flow	2.35 MG	3.34 MG	4.46 MG
Average Daily Flow	1.15 MG	1.60 MG	1.58 MG
Precipitation	4.45 IN	6.25 IN	6.70 IN
Percent Plant Capacity	57%	80%	79%
NPDES Violations	0	0	1

Additional Comments: Chlorination season officially started on 4/1.

Also replaced 2 pumps at Clifden Pond Lift Station and am in the process of replacing some old components within the panel.