



WASTEWATER DEPARTMENT

MONTHLY REPORT

STATS FOR MONTH	JUNE 2016	JUNE 2015	JUNE 2014
Total Flow	32.6 MG	41.6 MG	35.1 MG
Highest Daily Flow	1.805 MG	3.005 MG	1.633 MG
Average Daily Flow	1.087 MG	1.385 MG	1.168 MG
Precipitation	8.8 IN	9.2 IN	6.4 IN
Percent Plant Capacity	54%	69%	58%
NPDES Violations	1	1	0

Additional Comments:

The one violation for the month occurred on June 22nd after receiving 2.7 inches of rain. It was a high bacteria count from solids washing out of the secondary clarifiers. As per our permit, IDEM was notified of the incident and a follow up report was filed on June 23rd showing that we were back in compliance.

Merrell Bros hauled bio-solids from the treatment plant the week of June 13 – June 17. The total amount hauled was 306.5 tons.

The Departments first vac truck was delivered on 6/30/16. Employee training will be forthcoming in July.