



ZIONSVILLE WASTEWATER DEPARTMENT

MONTHLY REPORT

STATS FOR MONTH	JAN 2017	JAN 2016	JAN 2015
Total Flow Treated	40.42 MG	35.39 MG	34.93 MG
Highest Daily Flow	1.99 MG	1.69 MG	1.26 MG
Average Daily Flow	1.30 MG	1.14 MG	1.13 MG
Precipitation	4.34 IN	1.52 IN	2.09 IN
Percent Plant Capacity	65%	57%	56%
NPDES Violations	0	0	0

Additional Comments:

Merrell Bros. hauled biosolids out of the treatment plant on 1/19 and finished up on 1/20.

Precision Controls performed the annual effluent flow meter calibration on 1/23.

Cummins Crosspoint repaired the emergency generator at Lost Run Farms lift station on 1/26.