



ZIONSVILLE WASTEWATER DEPARTMENT

MONTHLY REPORT

MAY 2017

STATS FOR MONTH	MAY 2017	MAY 2016	MAY 2015
Total Flow	57.5 MG	29.9 MG	33.4 MG
Highest Daily Flow	4.950 MG	1.105 MG	1.628 MG
Average Daily Flow	1.856 MG	0.965 MG	1.078 MG
Precipitation	8.7 IN	2.4 IN	2.7 IN
Percent Plant Capacity	93%	48%	54%
NPDES Violations	1	0	0

Additional Comments: Hauled biosolids from the plant on 5/9 and 5/10. The work was completed by Merrell Brothers.

Had a very wet month of May. Recorded the highest daily rainfall on 5/4 with 2.30" and had another 1.08" the day before. Almost 50% of the days in May we recorded measurable rainfall.

At the end of the month on 5/30, had the department's first sanitary sewer overflow of the year from Boone Village Lift Station. It was due to mechanical failure at the station and has since been repaired. A permanent back up system is on order and will be installed later this summer to prevent this from happening again. As per our permit, a report was filed with IDEM describing the incident.