



WASTEWATER DEPARTMENT

MONTHLY REPORT

JUNE 2017

STATS FOR MONTH	JUNE 2017	JUNE 2016	JUNE 2015
Total Flow	35.4 MG	32.6 MG	41.6 MG
Highest Daily Flow	2.790 MG	1.805 MG	3.005 MG
Average Daily Flow	1.180 MG	1.087 MG	1.385 MG
Precipitation	5.8 IN	8.8 IN	9.2 IN
Percent Plant Capacity	59%	54%	69%
NPDES Violations	0	1	1

Additional Comments:

Work was completed on a VFD (Variable Frequency Drive) on an aeration blower to help with energy conservation. This will have an energy pay back of less than 3 years. The work was completed by Gardner Denver with electrical work completed in May by Gaylor Electric.

Had a bid opening for the 2017 Sewer Rehab Project on 6/22. Benchmark was the low bidder and will be receiving the Notice of Award. The project

will be starting later this summer and will include sewer main lining in areas of Sugarbush subdivision, Mulberry Street, and Bloor Lane.